

天津五十一站质量检验中心有限公司

检测报告

Tianjin Fifty-One Station Quality Inspection Center Co., Ltd.

Test Report

报告编号 (Report No.): WSY260175

第 1 页 共 3 页 (Page 1 of 3)

样品名称 (Sample name)	30kV insulating gloves	规格型号 (Model/Type)	30kV, 410mm±15mm
样品数量 (Quantity)	3pc	商标 (Brand)	金能电力JINPOWER
抽样基数/地点 (Sampling base/Place)	/	检测类型 (Test Category)	Type Test
样品描述 (Sample Description)	Orange	样品等级 (Sample Grade)	/
生产日期/批号 (Date/Batch Number)	/	到样日期 (Received Date)	06 February, 2026
检验时间 (Test Time)	2026-02-09 ~ 2026-02-16	试验环境 (Test Environment)	21℃ 48%
受检单位/地址/电话 (Inspection Unit/Add/Tel)	Hebei Jinneng Power Technology Co., Ltd. 联系人: Zhang Feiyan 10th Floor, Block B, Runjiang Huigu Building, No. 95 Qilian Street, High-tech Zone, Shijiazhuang, Hebei, China 电话: 0311-85837118		
生产单位/地址 (Manufacture Unit/Add)	Hebei Jinneng Power Technology Co., Ltd. 10th Floor, Block B, Runjiang Huigu Building, No. 95 Qilian Street, High-tech Zone, Shijiazhuang, Hebei, China		
检测依据 (Standard)	GB/T 17622-2008 "Live working-gloves of insulating material"		
检测项目 (Test Items)	Structure, Shape, Size, Thickness, Workmanship and Finish, Tensile Strength and Elongation at Break, Tension Set, Electrical Properties Requirements, Aging Resistance Requirements, Thermal Properties Requirements (Flame Resistance, Low Temperature Resistance), Marking		
检测结论 (Conclusion)	According to GB/T 17622-2008 "Live working-gloves of insulating material", all tested indicators meet the requirements of the standard. (印章) 河北金能电力科技股份有限公司 签发日期 2026年2月9日		
备注 (Note)	/		

批准 张蕊
(Approver)

审核 付晓超
(Checher)

[A] 提取文字 更多
(Editor)

量检
★
金测专

